

REPO FLOOR 22mm P6 CB Tongue & Groove Floorboard

Holder/Issued to

AS Repo Vabrikud

Maidla tee 7, EE-432 99 Püssi, Estonia

VAT number: EE100118517

Phone: +372 339 6000

E-mail: sales@sorbessgroup.com, Web: www.sorbessgroup.com

Product description

REPO flooring grade 22mm P6 chipboard with tongue and groove for joining in between beams and on beams.

Intended use

Load bearing floor boards for subfloors intended for joining between beams and on beams in load category A in climate class 1, safety classes 1 and 2.

Trade name

REPO FLOOR 22mm P6 spontad

Approval

The product has been found to meet the requirements in the following sections of Boverket Building Regulations (BBR) and Boverket mandatory provisions on application of the European construction standards (Eurocodes), (EKS): both issued by the National Board of Housing, Building and Planning.

BBR

Air, General

6:21

Durability

Materials

Design*

Calculation models and calculation methods*

Wood-based panels

Section G, Article 2

Section A, Article 17

Section A, Article 22

Section A, Article 23

Section G, EN 1995-1-1, 3.5

* Design according to applicable eurocodes and national choices in EKS.

Associated documents

Assembly instructions dated 2017-10-06

Certificate no. SC1734-12 | 2017-11-08

RISE Research Institutes of Sweden AB | Certification

Box 857, SE-501 15 Borås, Sverige

Tel: +46 10-516 50 00

certifiering@ri.se | www.ri.se

2017-08-18

Control

The factory production control (FPC) shall be performed according to instructions dated 2012 and is monitored by an independent inspection body.

Control agreement: VTT-A-00112-17, Inspection body: VTT.

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this approval and associated documents.

Manufacturing place

Production control includes the following place:

AS Repo Vabrikud, Püssi Estonia.

Marking

The product is to be marked at the factory.

The marking consists of a text on every product supplied and includes:

P-mark

Product type designation

Certificate number

Formaldehyde class

Consecutive manufacture no./date of production



Repo Floor 22mm P6 spontad

SC1734-12

E1

Date

The marking consists of a label on every packing supplied and includes:

Holder of certificate

P-mark

Certification body

Product type designation

Inspection body

AS Repo Vabrikud, Püssi Estland



RISE Certifiering

Repo Floor 22mm P6 spontad

VTT

Basis for judgement/approval

Declaration of Performance No. 001-2017, dated 2017-10-27 by AS Repo Vabrikud.

Reports PX22485 and PX28185 by SP Sveriges Tekniska Forskningsinstitut.

Surveillance Report VTT-Q-00403-01-17 dated 2017-09-21 by VTT Expert Services Ltd.

Comments

This approval supersedes the previous approval with the same number dated 2012-11-09.

Validity

Valid through 2022-11-07.

Leif Lundqvist

Marie Karlsson

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence.

Certificate no. SC1734-12 | 2017-11-08

RISE Research Institutes of Sweden AB | Certification